

# SIMULATOR OF PLANT FACTORY WITH ARTIFICIAL LIGHTING (PFAL)

Wei FANG, Ph.D., Professor  
Dept. of Biomechatronics  
Engineering  
National Taiwan University

# 大綱

簡介：全人工光型植物工廠

植物、環境與燈光配置

質能平衡：CO<sub>2</sub>, 水分, 能源

PFAL Simulator - Excel 版

## 簡介：PFAL

全人工光型植物工廠 (PFAL) 在密閉的環控室內栽培作物，幾乎不受天候與蟲害的影響，生產風險大幅降低。

PFAL 使用人工光，不導入日光，減少了日光每日變化與季節性變化的影響；使用保溫的外牆，也隔絕了室外溫度的影響，因此環境的調控變單純。

維持較高的氣密性 ( $ACH < 0.01$ ) 可讓較低溫且較高二氧化碳濃度的室內空氣得以維持在室內，節省二氧化碳與冷氣的成本

維持較高的氣密性可減少受室外溫、溼度影響

需要高效率 (高  $\mu\text{mol}/\text{J}$ ) 的人工光源

如萵苣或菠菜等，PPFD為 $200\sim 300 \mu\text{mol}/\text{m}^2/\text{s}$

## PFAL內需要補充二氧化碳

PFALs 通常比溫室小，CO<sub>2</sub>施肥不透過燃燒天然氣，通常使用液態CO<sub>2</sub>鋼瓶，透過電磁閥控制並隨時監測CO<sub>2</sub>濃度。

在PFAL中CO<sub>2</sub>濃度通常維持在1000 ppm

在PFAL中的室內溫度通常透過空調AC來控溫。

室內的溫、濕度通常維持在光合作用與植物生長或發育最適當的溫、濕度範圍。

溫度通常維持在定值並保持固定的日/夜溫差

## PFAL中使用多層的栽培架

- 通常至少會有 5 至 10 層來極大化單位土地面積的產能
- 燈光安裝在每一層
- 營養液透過循環系統輸送到每一層




營養液是含有水溶性礦物質的水溶液，植物透過根系吸收營養液，並將水分與營養成分（溶於水中的陰陽離子）輸送全株，最終由葉片的蒸散作用將水分送往空氣中。

- 因為蒸散作用，室內空氣的相對濕度Relative humidity/水蒸氣密度water vapor density/絕對溼度absolute humidity/水蒸汽壓water vapor pressure 增加。
- 在PFAL中，有時除溼設備是必要的，雖然空調設備啟動時，除溼會一併進行。但當溫度達設定值時，空調設備停機，但濕度可能仍高。
- 空調設備所冷凝的水分可導入水槽中重複使用。這是PFAL 的栽培用水量遠比溫室或田間栽培少很多的主因。

# 廠房：必備設施

1. Thermally insulated walls with very low ACH (nearly air tight)
2. AC with reused of condensed water
3. Multi-layer cultural bench
  - Artificial light for each layer
  - Circulating nutrient solution delivered to each layer
4. CO<sub>2</sub> enrichment
5. (De)humidifier
6. Monitoring and control



Culture room					
Room length	10 m	space utilization	0.5	Leaf area/plant	0.1 m <sup>2</sup> /plt
Room width	10 m	No. of layers	4	Number of plants	6000 plt/room
Room height	4 m	Culture area	200 m <sup>2</sup>	Total leaf area	600 m <sup>2</sup>
Room volume	400 m <sup>3</sup>	Cropping density	30 plts/m <sup>2</sup>	LAI	3

環控室體積 = 長 x 寬 x 高 = 10 x 10 x 4 = 400 m<sup>3</sup>

栽培面積 = 室內面積 x 空間利用率 x 栽培層數 = 100 x 0.5 x 4 = 200 m<sup>2</sup>

室內總株數 = 栽培面積 / 栽培密度 = 200 x 30 = 6000 株

總葉面積 = 單株葉片面積 x 總株數 = 0.1 x 6000 = 600 m<sup>2</sup>

葉面積指數 (LAI) = 總葉面積 / 栽培面積 = 600 / 200 = 3

# 密度

空氣、CO<sub>2</sub> 都視為理想氣體

$$28/0.0821/(273.15+25) = 1.14$$
$$28/0.0821(273.15+5) = 1.23$$

$$P V = n R T = m R T / M$$

一大氣壓下

$$V/m = RT/M$$

$$\text{Density} = m/V = M/RT$$

Environment	T, deg.C		RH, %	density = 1/SV
Leaf T	25	RH_leaf	100	1.14
indoor T	25	RH_in	80	1.14
outdoor T	5	RH_out	40	1.23
CO2 indoor (ppm)	1200	-> mg/m3	2157.5	1.80
CO2 outdoor (ppm)	410	-> mg/m3	790.2	1.93

$$44.01/0.0821/(273.15+25) = 1.7979$$

$$44.01/0.0821(273.15+5) = 1.927$$

# 植物與環境

Plant										
crop type (light)	std		Pm=	1.084		Pmax=	2.61	mg/(m2.s)		
crop type (CO2)	std		Rc=	959						
KI	100	W/m2	GI	0.53						
Kc	440	mg/m3	Gc	0.78				Ps: Photosynthesis	0.82 mg/(m2.s)	
CO2 in chloroplast	848.7	ppm		1525.9	mg/m3			Rp: Photorespiration	0.03 mg/(m2.s)	
Tm	25		GTI	1.0				Rd: Darkrespiration	0.10 mg/(m2s)	
a	5		Kpr	0.04				Pn: Net Photos.	0.69 mg/(m2.s)	
Rd(20C)	0.07		Q10	2.00						
Environment										
	T, deg.C		RH, %	density = 1/SV	VP, kPa	ah	Enthalpy,kJ/kg	VD, g/m3	VDD <sub>leaf-air</sub>	VDD <sub>in-out</sub>
Leaf T	25	RH_leaf	100	1.14	3.17			23.0		
indoor T	25	RH_in	80	1.14	2.53	0.016	65.77	18.4	4.6	
outdoor T	5	RH_out	40	1.23	0.35	0.002	10.42	2.7		15.7
CO2 indoor (ppm)	1200	-> mg/m3	2157.5	1.80			Pn/Tr =	0.100		
CO2 outdoor (ppm)	410	-> mg/m3	790.2	1.93			Tr/Pn =	10.038	Rav	100.0 s/m
Wind (m/s)	1	m/s	CropType	high	std	low			Rlv	200.0 s/m
			Rlv =	300	200	100			Rlv.inc	366.9 s/m
ACH	0.02	1/h	CropType	std	low				Rv.total	666.9 s/m
			Rlv.inc =	366.9	183.5				TR	6.90 mg/(m2.s)

光量與二氧化碳濃度都會影響氣孔阻力  
 作物的氣孔對前者分三種類型的反應：high、std.、low  
 作物的氣孔對後者分兩種類型的反應：std.、low

# 作物的氣孔對輻射量分三種類型的反應： high、std.、low

high

$$=IF(PAR>80,300,1400-PAR*(1400-300)/80)$$

std

$$=IF(PAR>80,200,1200-PAR*(1200-200)/80)$$

low

$$=IF(PAR>80,100,1000-PAR*(1000-100)/80)$$

$$PAR閾值 = 80 \text{ W m}^{-2} = 80 * 4.6 = 368 \text{ } \mu\text{mol m}^{-2} \text{ s}^{-1}$$

# 作物的氣孔對CO<sub>2</sub>濃度分兩種類型的反應： std.、low

std

$$=IF(\text{CO2in\_mg}>=2352,400,400*\text{CO2in\_mg}/2352)$$

low

$$=IF(\text{CO2in\_mg}>=2352,200,200*\text{CO2in\_mg}/2352)$$

$$\text{CO}_2\text{閾值} = 2352 \text{ mg m}^{-3} = 1200 \text{ ppm} * \text{density of CO}_2$$



# 光合能力：最大光合速率

- 光合能力代表最大光合速率

**Photosynthetic capacity** ( $P_{\max}$ ) is a measure of the maximum rate at which leaves are able to fix carbon during photosynthesis.

- 常用單位： the amount of carbon dioxide that is fixed per meter squared per second, for example as  $\mu\text{mol m}^{-2} \text{sec}^{-1}$ .



- 增加葉片上的氣孔數量可以提升光合能力

Tanaka, Y., S. S. Sugano, T. Shimada, and I. Hara-Nishimura. 2013. Enhancement of leaf photosynthetic capacity through increased stomatal density in *Arabidopsis*. *New Phytologist* **198**: 757–764.



# 光合能力：最大光合速率

$0.8 \text{ mg CO}_2 \text{ m}^{-2} \text{ s}^{-1}$

$20 \text{ } \mu\text{mol CO}_2 \text{ m}^{-2} \text{ s}^{-1}$




$$20 \mu\text{mol CO}_2 \text{ m}^{-2} \text{ s}^{-1} = 0.88 \text{ mg CO}_2 \text{ m}^{-2} \text{ s}^{-1}$$



from the end of the vein xylem to the gas-exchange epidermis

Across the diverse range of land plant diversity sampled, an intimate association between **light-saturated net CO<sub>2</sub> assimilation rate** ( $A_{max}$ ) and **the hydraulic conductance** ( $K_{leaf}$ ) of whole leaves was found

Tim J. Brodribb, Taylor S. Feild, Gregory J. Jordan. 2007. **Leaf Maximum Photosynthetic Rate and Venation Are Linked by Hydraulics** 葉片水力學. *Plant Physiology*, Volume 144, Issue 4, August 2007, Pages 1890-1898, <https://doi.org/10.1104/pp.107.101352>




### A. 單脈葉中 $A_{max}$ 對葉寬的敏感性

$A_{max}$  隨著葉變窄而增加

只有從葉脈到氣孔的最大距離  
小於幾百微米的物種才能實現高光合速率

圖中顯示了五個代表性物種的大致位置




### B. 葉脈密度對葉片 $A_{max}$ 的影響

從葉脈到表皮的葉厚度為 70、100 和 130  $\mu\text{m}$


$A_{max}$  隨著葉片變薄而增加

# 光合能力：最大光合速率

$12 \mu\text{mol CO}_2 \text{ m}^{-2} \text{ s}^{-1}$



$18 \mu\text{mol CO}_2 \text{ m}^{-2} \text{ s}^{-1}$




# 光合能力 最大光合速率

Sun leaves:

$$10 \mu\text{mol CO}_2 \text{ m}^{-2} \text{ s}^{-1}$$

Shade leaves:

$$6 \mu\text{mol CO}_2 \text{ m}^{-2} \text{ s}^{-1}$$



# 蒸散效率 Transpiration Efficiency (TE)

$TE = P_n / Tr$  又稱  $CO_2$ /vapor exchange rate

TE 隨著 PPFD 與  $CO_2$  濃度增加而增加  
應該是因為氣孔阻力增加之故

VPD 較低 (1.1 kPa) 時的 TE 高於 VPD 較高 (2.2 kPa) 時的 TE，前者約是後者的 1.37 倍

番茄葉片的 TE 範圍大致在  $0 \sim 0.03 \text{ mg/m}^2/\text{s}$




Fig. 2. Effect of ambient conditions on **transpiration efficiency (TE)** of tomato leaves (ratio of weight of assimilated  $\text{CO}_2$  to weight of transpired water). Left panel: effect of light (Photosynthetic Photon Flux Density, x-axis) and  $\text{CO}_2$  concentration (symbols at right), measured at  $25^\circ\text{C}$  leaf temperature and 1.1 kPa vapour pressure deficit. Right panel: effect of humidity. On the y-axis are the measurements shown at left, on the x-axis are the corresponding measurements done at a VPD of 2.2 kPa.



# 更改 作物對光量與二氧化碳濃度的反應類型

兩者都改為 low,  $R_{lv}$  與  $R_{lv.inc}$  均下降

Plant																	
crop type (light)	low	Pm=	0.365	Pmax=	0.88 mg/(m2.s)												
crop type (CO2)	low	Rc=	562														
KI	100 W/m2	GI	0.53														
Kc	440 mg/m3	Gc	0.78														
CO2 in chloroplast	848.7 ppm	1525.9 mg/m3															
Tm	25	GTI	1.0														
a	5	Kpr	0.04														
Rd(20C)	0.07	Q10	2.00														
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Ps: Photosynthesis</td> <td>0.30 mg/(m2.s)</td> </tr> <tr> <td>Rp: Photorespiration</td> <td>0.01 mg/(m2.s)</td> </tr> <tr> <td>Rd: Darkrespiration</td> <td>0.10 mg/(m2.s)</td> </tr> <tr> <td>Pn: Net Photos.</td> <td>0.19 mg/(m2.s)</td> </tr> </table>										Ps: Photosynthesis	0.30 mg/(m2.s)	Rp: Photorespiration	0.01 mg/(m2.s)	Rd: Darkrespiration	0.10 mg/(m2.s)	Pn: Net Photos.	0.19 mg/(m2.s)
Ps: Photosynthesis	0.30 mg/(m2.s)																
Rp: Photorespiration	0.01 mg/(m2.s)																
Rd: Darkrespiration	0.10 mg/(m2.s)																
Pn: Net Photos.	0.19 mg/(m2.s)																
Environment																	
T, deg.C		RH, %	density = 1/SV	VP, kPa	ah	Enthalpy,kJ/kg	VD, g/m3	VDD <sub>leaf-air</sub>	VDD <sub>in-out</sub>								
Leaf T	25	RH <sub>leaf</sub>	100	1.14	3.17		23.0										
indoor T	25	RH <sub>in</sub>	80	1.14	2.53	0.016	65.77	18.4	4.6								
outdoor T	5	RH <sub>out</sub>	40	1.23	0.35	0.002	10.42	2.7	15.7								
CO2 indoor (ppm)	1200 -> mg/m3	2157.5	1.80			Pn/Tr =	0.0157										
CO2 outdoor (ppm)	410 -> mg/m3	790.2	1.93			Tr/Pn =	63.898	Rav	100.0 s/m								
Wind (m/s)	1 m/s	CropType	high	std	low												
		Rlv =	300	200	100	Rlv	100.0 s/m	Rlv.inc	183.5 s/m								
ACH	0.02 1/h	CropType	std	low													
		Rlv.inc =	366.9	183.5													
		Rv.total					383.5 s/m	Tr	12.00 mg/(m2.s)								

Pn 微幅增加 (0.18 → 0.19, +5.5%) , Tr 大幅增加 (6.9 → 12, +74%)

結果：Pn/Tr 大幅降低 (0.0268 → 0.0157, -41.4%)

# 更改 作物對光量與二氧化碳濃度的反應類型 前者改為 high，後者維持 std

Plant										
crop type (light)	high		Pm=	0.327		Pmax=	0.88 mg/(m2.s)			
crop type (CO2)	std		Rc=	1099						
KI	100 W/m2		GI	0.48						
Kc	440 mg/m3		Gc	0.78			Ps: Photosynthesis	0.26 mg/(m2.s)		
CO2 in chloroplast	848.7 ppm			1525.9 mg/m3			Rp: Photorespiration	0.01 mg/(m2.s)		
Tm	25		GTI	1.0			Rd: Darkrespiration	0.10 mg/(m2s)		
a	5		Kpr	0.04			Pn: Net Photos.	0.15 mg/(m2.s)		
Rd(20C)	0.07		Q10	2.00						
Environment										
	T, deg.C		RH, %	density = 1/SV	VP, kPa	ah	Enthalpy,kJ/kg	VD, g/m3	VDD <sub>leaf-air</sub>	VDD <sub>in-out</sub>
Leaf T	25	RH_leaf	100	1.14	3.17			23.0		
indoor T	25	RH_in	80	1.14	2.53	0.016	65.77	18.4	4.6	
outdoor T	5	RH_out	40	1.23	0.35	0.002	10.42	2.7		15.7
CO2 indoor (ppm)	1200	-> mg/m3	2157.5	1.80			Pn/Tr =	0.0258		
CO2 outdoor (ppm)	410	-> mg/m3	790.2	1.93			Tr/Pn =	38.735		
Wind (m/s)	1	m/s	CropType	high	std	low		Rav	100.0 s/m	
			Rlv =	300	200	100		Rlv	300.0 s/m	
								Rlv.inc	366.9 s/m	
ACH	0.02	1/h	CropType	std	low			Rv.total	766.9 s/m	
			Rlv.inc =	366.9	183.5			Tr	6.00 mg/(m2.s)	

Pn 降低 (0.18 → 0.15, -16.7%)，Tr 也降低 (6.9 → 6.0, -13%)，但幅度較小  
結果：Pn/Tr 微幅降低 (0.0268 → 0.0258, -3.7%)

當輻射量低於低限 ( $80 \text{ W m}^{-2}$ )， $R_{lv}$  氣孔阻力會大幅增加 ( $300 \rightarrow 767.5$ )

Plant											
crop type (light)	high		Pm=	0.215		Pmax=	0.88	mg/(m2.s)			
crop type (CO2)	std		Rc=	1753							
KI	100	W/m2	GI	0.32							
Kc	440	mg/m3	Gc	0.78					Ps: Photosynthesis	0.17	mg/(m2.s)
CO2 in chloroplast	848.7	ppm		1525.9	mg/m3				Rp: Photorespiration	0.01	mg/(m2.s)
Tm	25		GTI	1.0					Rd: Darkrespiration	0.10	mg/(m2.s)
a	5		Kpr	0.04					Pn: Net Photos.	0.07	mg/(m2.s)
Rd(20C)	0.07		Q10	2.00							
Environment											
	T, deg.C		RH, %	density = 1/SV	VP, kPa	ah	Enthalpy,kJ/kg	VD, g/m3	VDD <sub>leaf-air</sub>	VDD <sub>in-out</sub>	
Leaf T	25	RH <sub>leaf</sub>	100	1.14	3.17			23.0			
indoor T	25	RH <sub>in</sub>	80	1.14	2.53	0.016	65.77	18.4	4.6		
outdoor T	5	RH <sub>out</sub>	40	1.23	0.35	0.002	10.42	2.7		15.7	
CO2 indoor (ppm)	1200	-> mg/m3	2157.5	1.80			Pn/Tr =	0.0182			
CO2 outdoor (ppm)	410	-> mg/m3	790.2	1.93			Tr/Pn =	55.051	Rav	100.0	s/m
Wind (m/s)	1	m/s	CropType	high	std	low			Rlv	767.5	s/m
			Rlv =	767.5	625	482.5			Rlv.inc	366.9	s/m
ACH	0.02	1/h	CropType	std	low				Rv.total	1234.4	s/m
			Rlv.inc =	366.9	183.5				Tr	3.73	mg/(m2.s)

$P_n$  大幅降低 ( $0.18 \rightarrow 0.07$ , -61%)， $T_r$  大幅降低 ( $6.9 \rightarrow 3.73$ , -46%)

結果： $P_n/T_r$  降低 ( $0.0268 \rightarrow 0.0182$ , -32%)



# 燈光配置與光量

Lighting									
W per LEDtube	20 W/lamp	Number of LEDtubes	1818	PAR	80 W/m <sup>2</sup>				
No.LEDtube/layer	6	PPFD	370 $\mu\text{mol}/\text{m}^2/\text{s}$	DLI	21.312 $\text{mol}/\text{m}^2/\text{day}$				
Bench area per layer	0.66 m <sup>2</sup>	Light Period	16 h/day	Power consumpti	181.82 W/m <sup>2</sup>				
Total W of other equip (W <sub>e</sub> )	80 W/room	Total W of lamps	36360.00 W/room						

**PAR (W m<sup>-2</sup>) = PPFD / 4.6 → PPFD 大於 370, PAR 大於 80 此為 R<sub>lv</sub> 的閾值**

DLI = PPFD ( $\mu\text{mol m}^{-2}\text{s}^{-1}$ ) x LP (給光時數L) x 3.6 / 1000 = 14.4  $\text{mol m}^{-2}\text{day}^{-1}$

總燈管數 = 栽培面積 x 每層安裝燈管數 / 單層面積 = 200 x 6 / 0.66 = 1818

總耗電量 = 總燈管數 x 單支燈管耗電量 = 1818 x 20 = 36360 W

單位面積耗電量 = 36360 / 200 = 181.8 W m<sup>-2</sup>

質量守恆

CO<sub>2</sub> BALANCE

CO2 balance		
LA per plant	0.1	m2/plant
Number of plants	6000	plants/room
Pn	0.7	mg/m2/s
ACH	0.1	1/h
Room volumn	400	m3

	ppm	mg/m3
CO <sub>2</sub> in	1200	2157.5
CO <sub>2</sub> out	410	790.2

C <sub>N</sub> per room	412.5	mg/s/room
CO <sub>2</sub> absorbed by plants		
C <sub>v</sub> per room	15.2	mg/s/room
CO <sub>2</sub> loss by ventilation		
C <sub>s</sub> per room	427.6	mg/s/room
CO <sub>2</sub> supply to room		

$$C_s = C_v + C_N$$

ation

CO2 balance

Water balance

Energy balance



$$C_N = P_N \times L = P_N \times LA.plt \times Num.plt$$

$P_N$  : Net photosynthesis rate per leaf area, mg/(m<sup>2</sup>s)

$L$  : Total leaf area in a room, m<sup>2</sup>/room

$$C_N = 1 * (0.02 * 100) = 2 \text{ mg/(s.room)}$$

$$C_V = A \times (\rho_{ca in} - \rho_{ca out}) \times V_r$$

$A$  : Ventilation rate, 1/h


$V_r$  : Interior Volume

$\rho_{ca in}$  : Inside CO<sub>2</sub> concentration, mg/m<sup>3</sup>

$\rho_{ca out}$  : Outside CO<sub>2</sub> concentration, mg/m<sup>3</sup>

$$C_V = 0.02 * (1799.5 - 733) * 500 / 3600 = 2.9625 \text{ mg/s}$$

$$C_s = C_v + C_N = 2 + 2.96 = 4.96 \text{ mg/s}$$




### Simulation

LA per plant	<input type="text" value="0.02"/>	m <sup>2</sup> /plant	Num. of plants	<input type="text" value="100"/>	plants/room
Room length	<input type="text" value="10"/>	m	Room width	<input type="text" value="10"/>	m
Room height	<input type="text" value="5"/>	m	Room volume	<input type="text" value="500.0"/>	m <sup>3</sup> /room
A	<input type="text" value="0.02"/>	1/h			
1) Room net photos. rate(CN)	<input type="text" value="2.0"/>	mg/(s room)			
Net photos. rate per unit leaf area	<input type="text" value="1.0"/>	mg/(m <sup>2</sup> s)			
2) CO <sub>2</sub> loss by ventiration(CV)	<input type="text" value="3.0"/>	mg/(s room)			
CO <sub>2</sub> conc. in	<input type="text" value="1000"/>	ppm	<input type="text" value="1799.5"/>	mg/m <sup>3</sup>	
CO <sub>2</sub> conc. out	<input type="text" value="380"/>	ppm	<input type="text" value="733.0"/>	mg/m <sup>3</sup>	
3) CO <sub>2</sub> supply to room(CS)	<input type="text" value="5.0"/>	mg/(s room)			

質量守恆

WATER BALANCE





蒸散產生的水汽量 (2) 小於換氣的排濕量 (43.6) ,  
 此時則需要**啟動加濕機**才能維持設定的室內濕度

## Simulation

Temp. in	25	C	RH in	80	%	Vds in	18.4	g/m <sup>3</sup>	= 23.01 * 0.8
Temp. out	5	C	RH out	40	%	Vds out	2.7	g/m <sup>3</sup>	= 6.79 * 0.4
LA per plant	0.02	m <sup>2</sup> /plant				Num. of plants	100	plants/room	
Room length	10	m	Room width	10	m	Room height	5	m	
Room volume	500.0	m <sup>3</sup> /room				A	0.02	1/h	

1) Transpiration rate of room(TR)

2.0 mg/(s room)

TR per unit leaf area

1.0 mg/(m<sup>2</sup> s)

2) Water loss by ventiration(VW)

43.6 mg/(s room)

3) Humidification(H)

41.6 mg/(s room)

4) Dehumidification(D)

0.0 mg/(s room)

		Temperature, °C					
		0	5	10	15	20	25
Relative humidity, %	0	0.00	0.00	0.00	0.00	0.00	0.00
	20	0.97	1.36	1.88	2.56	3.45	4.60
	40	1.94	2.72	3.76	5.13	6.91	9.20
	60	2.91	4.08	5.64	7.69	10.36	13.81
	80	3.87	5.43	7.51	10.25	13.82	18.41
	100	4.84	6.79	9.39	12.82	17.27	23.01

$$T_R = Tr * L = 1 * 2 = 2 \text{ mg/(s.room)}$$

$$V_w = 0.02 * (18.41 - 2.72) * 500 / 3600 = 0.0436 \text{ g/(s.room)} = 43.6 \text{ mg/(s.room)}$$

$$TR + H = D + V_w, 2 + H = D + 43.6, D=0 \text{ (no dehumidification)}, H = 43.6 - 2 = 41.6$$

能量守恒

ENERGY BALANCE

進入溫室的熱量以潛熱( $Q_L$ )+顯熱( $Q_S$ )兩種方式呈現

- 荷蘭的相對濕度低， $Q_L$ 占比較低，但也有近半  $1000/1900 = 52.63\%$ ，其餘為 $Q_S$   $900/1900 = 47.37\%$
- 南歐如西班牙濕度高， $Q_S$ 占比更低  $350/2000 = 17.5\%$ ， $Q_L$ 占比高  $1650/2000 = 82.5\%$

台灣的天氣與南歐相近，濕度都偏高，尤其是在夜間，特別是沒有加熱的溫室內。換言之，空調作用於除溼的比例頗高。氣密性不高的 PFAL，也存在這種困擾。

	deg.C		%	density	VP, kPa	ah, kg/kg	Enthalpy,kJ	VD, g/m3	VDD <sub>leaf-air</sub>	VDD <sub>in-out</sub>
T <sub>leaf</sub>	25	RH <sub>leaf</sub>	100	1.14	3.17			23.01		
T <sub>in</sub>	25	RH <sub>in</sub>	80	1.14	2.53	0.016	65.77	18.41	4.602	
T <sub>out</sub>	5	RH <sub>out</sub>	40	1.23	0.35	0.002	10.42	2.72		15.69
Room dimension		Lg	10	Wd	10.00	Hgh	4.00 m			
Room volume	400 m3		ACH	0.02			k <sub>w</sub> (conductivity of walls) =		0.10	

### Energy balance

$$W_L + W_e = Q_v + Q_c + Q_a$$

Total W of lamps (W<sub>L</sub>) 36360.0 W/room, Total W of other equip. (W<sub>e</sub>) 80.0 W/room

Heat loss by ventilation (Q<sub>v</sub>) 140.7 W/room


$$Q_v = (Enth_{in} - Enth_{out}) * Density_{in} * VolofRoom * ACH / 3.6$$

Heat loss by conduction (Q<sub>c</sub>) 720.0 W/room

$$Q_c = 2*(Lg*Wid+Wid*Hgh+Lg*Hgh) * Kw * (Tin - Tout)$$

Heat carry away by AC (Q<sub>a</sub>) 35579.3 W/room

$$Q_a = W_L + W_e - Q_v - Q_c$$



**Simulation**

Temp. in	25 C	RH in	80 %	LA per plant	0.02 m <sup>2</sup> /plant
Temp. out	5 C	RH out	40 %	Num. of plants	100 plants/room
Lamp type	INF	Total W of lamps	8000 W/room		
Room length	10 m	Room width	10 m	Room height	5 m
Room volume	500.0 m <sup>3</sup> /room	A	0.02 1/h		

Heat production by lamps( $Q_{SL}$ )	5118.7 J/(s room)
Short wave radiation( $S$ )	1231.1 J/(s room)
Long wave radiation( $L$ )	1650.2 J/(s room)
Heat loss by ventiration( $Q_V$ )	176.0 J/(s room)
Heat loss by conduction( $Q_C$ )	800.0 J/(s room)
Heat carried away by AC( $Q_A$ )	7024.0 J/(s room)

此三個數值與所選擇的燈具有關  
但最後納入其它計算的是  
燈具的總耗電 ( $W_L$ )

所以就算選用的燈具種類不同  
也不影響模式的實用性

濕空氣所含的熱量可分兩部分計算，兩者合計即為熱焓值(enthalpy):

1. 顯熱 Sensible heat of 1 kg air

$$H_s \text{ (in J/kg)} = T * C_p$$

2. 潛熱 Latent heat of 1 kg air:

$$H_L \text{ (in J/kg)} = W_x * V_d / \rho_{air} = W_x * AH$$

$H_S$  : Sensible Heat, J/kg

$T$  : Temperature, C

\* Conversion from J/g to J/kg is 1000 g/kg

$H_L$  : Latent Heat, J/kg

$W_x$  : Vaporization Heat of Water, J/kg

$V_d$  : Water Vapor Density, kg/m<sup>3</sup>

$\rho_{air}$  : Air Density, kg/m<sup>3</sup>

假設室內溫、濕度均高於室外， $H_s$  與  $H_L$  透過牆壁與孔隙對外傳出。

室內的熱量主要來自燈光與其他設備的電力消耗 ( $W_L$  and  $W_e$ )，一般假設電能消耗量等於傳入的熱量。當室溫維持定值，能量守恆式如下：

$$W_L + W_e = Q_V + Q_c + Q_a$$

	Temperatu	RH	density = 1/SV	Vps	ah	enthalpy,kJ/kg		
Leaf (oC)	25	RHleaf,%	100	1.14	3.17		Vds leaf	23.0 g/m3
indoor (oC)	25	RHin,%	80	1.14	3.17	0.016	Vd in	18.4 g/m3
outdoor (°C)	5	RHout,%	40	1.23	0.87	0.002	VDD	4.6 g/m3

$$H_s = 25 * 1006 \text{ J/kg.K} = 25.15 \text{ kJ/kg}$$

$$W_x = 2441.7 \text{ kJ/kg vapor @ } 25 \text{ }^\circ\text{C}$$

$$H_L = 2441.7 * 0.016 \text{ kg vapor/kg air} = 39.06 \text{ kJ/kg air}$$

$$H_s + H_L = 64.21 \text{ kJ/kg}$$
 此即為室內空氣的熱焓值

但此二數值並不是前頁提到的 S 與 L

Temperature	Vapor pressure	Heat of vaporization, $\Delta H_{vap}$			
		[J/mol]	[kJ/kg]	[Wh/kg]	[Btu(IT)/lb <sub>m</sub> ]
[°C]	[kPa] [100°bar]				
0.01	0.61165	45054	2500.9	694.69	1075.2
2	0.70599	44970	2496.2	693.39	1073.2
4	0.81355	44883	2491.4	692.06	1071.1
10	1.2282	44627	2477.2	688.11	1065.0
14	1.5990	44456	2467.7	685.47	1060.9
18	2.0647	44287	2458.3	682.86	1056.9
20	2.3393	44200	2453.5	681.53	1054.8
25	3.1699	43988	2441.7	678.25	1049.7
30	4.2470	43774	2429.8	674.94	1044.6

$W_L$  : Electrical energy supplied to lamps, J/s

$W_e$  : Electrical energy supplied to other equipment in a room, J/s

$Q_V$  : Heat by ventilation, J/s


$Q_c$  : Conduction heat, J/s

$Q_a$  : Exhaust heat from air conditioners, J/s

# 其它的電力設備產生的熱量 $W_e \rightarrow Q_e$


AC系統有室內、外機，只需考量室內機的風扇所消耗的電力

除濕機非長時間運轉， $CO_2$  施肥如使用鋼瓶，都可忽略



通常以此些設備的耗電量估算產生的熱量

圖中未包括營養液循環系統的馬達等



燈光的耗電量 = 產生的總熱量

$$W_L = Q_{SL} + S + L$$

- $Q_{SL}$  : Amount of heat production by lamps, J/s
- $S$  : Amount of energy of shortwave radiation, J/s
- $L$  : Amount of energy of long-wave radiation, J/s

$$Q_V = (E_{in} - E_{out}) \times \rho_{air} \times A \times V_r$$


- $E_{in}$  : Inside enthalpy, J/kg
- $E_{out}$  : Outside enthalpy, J/kg
- $A$  : Ventilation rate, 1/h
- $V_r$  : Volume of a room, m<sup>3</sup>

透過孔隙換氣排出的熱量


$$Q_c = (T_{in} - T_{out}) \times K_w \times A_r$$

- $T_{in}$  : Inside temperature, C
- $T_{out}$  : Outside temperature, C
- $K_w$  : Heat conduction coefficient, J/(s m<sup>2</sup> C)
- $A_r$  : wall, ceiling, and floor area, m<sup>2</sup>

透過牆壁傳導傳出的熱量



當  $Q_V$  與  $Q_C$  不足以傳出所有的熱 ( $Q_{SL} + S + L + Q_e$ ) 時



就需要  
空調設備  
 $Q_a$  來散熱

空調的降  
溫負荷可  
由此計算

## Simulation

Temp. in	25	C	RH in	80	%	LA per plant	0.02	m <sup>2</sup> /plant
Temp. out	5	C	RH out	40	%	Num. of plants	100	plants/room
Lamp type	INF				Total W of lamps		8000	W/room
Room length	10	m	Room width	10	m	Room height	5	m
Room volume	500.0		m <sup>3</sup> /room		ACH		0.02	1/h

$$W_L = Q_{SL} + S + L$$

Heat production by lamps(Q<sub>SL</sub>)

5118.7 J/(s room)

Short wave radiation(S)

1231.1 J/(s room)

Long wave radiation(L)

1650.2 J/(s room)

Heat loss by ventilation (Q<sub>V</sub>)

176.0 J/(s room)

Heat loss by conduction(Q<sub>C</sub>)

800.0 J/(s room)

Heat carried away by AC(Q<sub>A</sub>)

7024.0 J/(s room)

Inside enthalpy (h) = 65.81  
 Outside h = 10.42 kJ/kg  
 dh = 65.81 - 10.42 = 55.39  
 $Q_v = dh * 1.14 * 500 * 0.02 / 3.6 = 178 \text{ J/s} = \text{W}$   
 $Q_c = (25 - 5) * k * (400) = 800 \text{ W}$   
 假設熱導係數 k = 0.1  
 空調降溫負荷 Q<sub>a</sub> =  
 8000 - 178 - 800 = 7022 W  
 $W_L + W_e = Q_v + Q_c + Q_a$

The logo features a white, scalloped-edged circular shape centered on a bright yellow background. A horizontal red bar with rounded ends is superimposed across the middle of the white shape. The text "PFAL Simulator" is written in white, bold, sans-serif font on the red bar.

# PFAL Simulator

## 左側為資料輸入區

Plant									
crop type (light)	std	Pm=	0.241	Pmax=	0.88 mg/(m2.s)				
crop type (CO2)	std	Rc=	1408	Photosynthetic Capacity					
KI	100 W/m2	GI	0.35						
Kc	440 mg/m3	Gc	0.78						
CO2 in chloroplast	848.7 ppm	1525.9 mg/m3							
Tm	25	GTI	1.0	Ps: Photosynthesis 0.19 mg/(m2.s)					
a	15	Kpr	0.04	Rp: Photorespiration 0.01 mg/(m2.s)					
Rd(20C)	0.07	Q10	2.00	Rd: Darkrespiration 0.10 mg/(m2.s)					
				Pn: Net Photos. 0.09 mg/(m2.s)					
Environment									
T, deg.C		RH, %	density = 1/SV	VP, kPa	ah	Enthalpy, kJ/kg	VD, g/m3	VDD <sub>leaf-air</sub>	VDD <sub>in-out</sub>
Leaf T	25 RH_leaf	100	1.14	3.17			23.0		
indoor T	25 RH_in	80	1.14	2.53	0.016	65.77	18.4	4.6	
outdoor T	5 RH_out	40	1.23	0.35	0.002	10.42	2.7		15.7
CO2 indoor (ppm)	1200 -> mg/m3	2157.5	1.80	Pn/Tr = 0.0189 = Transpiration Efficiency (TE)					
CO2 outdoor (ppm)	410 -> mg/m3	790.2	1.93	Tr/Pn = 53.012		Rav 100.0 s/m			
Wind (m/s)	1 m/s	CropType	high std low	Rlv = 652.7174 520.6522 388.587		Rlv 520.7 s/m			
ACH	0.02 1/h	CropType	std low	Rlv.inc = 366.9 183.5		Rlv.inc 366.9 s/m			
				Rv.total = 987.6 s/m		Tr 4.66 mg/(m2.s)			
Culture room									
Room length	10 m	space utilization	0.5	Leaf area/plant 0.1 m2/plt		Number of plants 6000 plt/room			
Room width	10 m	No. of layers	4	Total leaf area 600 m2		LAI 3			
Room height	4 m	Culture area	200 m2						
Room volume	400 m3	Cropping density	30 plts/m2						
Lighting									
W per LEDtube	20 W/lamp	Number of LEDtubes	1818	PAR 54 W/m2					
No.LEDtube/layer	6	PPFD	250 $\mu\text{mol}/\text{m}^2/\text{s}$	DLI 14.4 mol/m2/day					
Bench area per layer	0.66 m2	Light Period	16 h/day	Power consump./ cural area 181.82 W/m2					
Total W of other equip (W <sub>e</sub> )	80 W/room			Total W of lamps 36360.00 W/room					

## 右側為計算結果

O2 balance				CO2 Price			
CO2 supply to room (C <sub>s</sub> )	55.78 mg/(s.room)	CO2 used	per day	kg CO2	cost,NT\$	Ratio	
Net photos. rate in room (C <sub>N</sub> )	52.74 mg/(s.room)	NT\$/kg	/day/plant	0.0005	0.0107	2.32	6
CO2 loss by ventilation (C <sub>v</sub> )	3.04 mg/(s.room)		/day/m2 room	0.0321			
C <sub>s</sub> = C <sub>N</sub> + C <sub>v</sub>			per month	96.39	1928		
				per year	1172.69	23,454	
Water balance				Elec.fee: Light			
Transpiration rate of room (T <sub>R</sub> )	2795.9 mg/(s.room)	Light elec	36.44 kW/room	cost,NT\$			
(De)Humidification (H)	-2761.0 mg/(s.room)	3.5	583 kWh per day	2041	73.7		
Water loss by ventilation (V <sub>w</sub> )	34.9 mg/(s.room)	NT\$/kWh	17491 kWh per month	61,219			
T <sub>R</sub> +H = V <sub>w</sub>		Light Period	0.097 kWh /day/plant				
				16	5.83 kWh/day/m2 room		
				212810 kWh per year	744,834		
Energy balance				Elec.fee: AC			
k (conductivity of walls) = 0.1				AC_elec	11.86 kW/room	cost,NT\$	
Total W of lamps (W <sub>L</sub> )	36360.0 W/room	COP	190 kWh per day	664	24.0		
Total W of other equipment (W <sub>e</sub> )	80 W/room		0.032 kWh/day/plant				
Heat loss by ventilation (Q <sub>v</sub> )	140.7 W/room		1.898 kWh/day/m2 room				
Heat loss by conduction (Q <sub>c</sub> )	720 W/room		5693 kWh per month	19924			
Heat carry away by AC (Q <sub>a</sub> )	35579.3 W/room		69261 kWh per year	242,414			
W <sub>L</sub> + W <sub>e</sub> = Q <sub>v</sub> + Q <sub>c</sub> + Q <sub>a</sub>		Capacity of AC required	10.108 RT, Note: 3.52 kW per Refri. Ton				
				Operating cost (CO2 + AC & Light Elec)			
				Ratio of OP cost		EY 100 g/kWh	
				per day	2769 NT\$	Yield 58.3 kg/day	
				per month	83,071 NT\$	1749 kg/month	
				per year	1,010,701 NT\$	20989 kg/year	
ACH	0.02	CO2	2.32%	Light elec	73.7%	AC elec	24.0%

四個工作表單

# 整廠模擬的輸出結果 (ACH = 0.01, indoor CO<sub>2</sub> = 800 ppm, COP = 3)

CO2 balance		
CO2 supply to room (C <sub>S</sub> )	26.78	mg/(s.room)
Net photos. rate in room (C <sub>N</sub> )	26.06	mg/(s.room)
CO2 loss by ventilation (C <sub>V</sub> )	0.72	mg/(s.room)
C <sub>S</sub> = C <sub>N</sub> + C <sub>V</sub>		

Water balance		
Transpiration rate of room (T <sub>R</sub> )	3191.1	mg/(s.room)
(De)Humidification (H)	-3173.7	mg/(s.room)
Water loss by ventilation (V <sub>W</sub> )	17.4	mg/(s.room)
T <sub>R</sub> +H = V <sub>W</sub>		

Energy balance		
k (conductivity of walls) =		0.1
Total W of lamps (W <sub>L</sub> )	36360.0	W/room
Total W of other equipment (W <sub>e</sub> )	80	W/room
Heat loss by ventilation (Q <sub>v</sub> )	70.3	W/room
Heat loss by conduction (Q <sub>c</sub> )	720	W/room
Heat carry away by AC (Q <sub>a</sub> )	35649.7	W/room
W <sub>L</sub> + W <sub>e</sub> = Q <sub>v</sub> + Q <sub>c</sub> + Q <sub>a</sub>		

CO2 Price	CO2 used	kg CO2	cost,NT\$	Ratio
20	per day	1.54	31	1.13%
NT\$/kg	/day/plant	0.0003	0.0051	
	/day/m2 room	0.0154		
	per month	46.27	925	
	per year	562.94	11,259	

Elec.fee: Light	Light elec	cost,NT\$	Ratio
3.5	36.44 kW/room		
NT\$/kWh	583 kWh per day	2041	74.6%
	Light Period	0.097 kWh /day/plant	
	16	5.83 kWh/day/m2 room	
		17491 kWh per month	61,219
		212810 kWh per year	744,834

Elec.fee: AC	AC_elec	cost,NT\$	Ratio
3	11.88 kW/room		
COP	190 kWh per day	665	24.3%
	0.032 kWh/day/plant		
	1.901 kWh/day/m2 room		
	5704 kWh per month	19964	
	69398 kWh per year	242,893	
Capacity of AC required		10.128 RT, Note: 3.52 kW per Refri. Ton	

Operating cost (CO2 + AC & Light Elec)						
Ratio of OP cost				per day	2737	NT\$
ACH	CO2	Light elec	AC elec	per month	82,108	NT\$
0.01	1.13%	74.6%	24.3%	per year	998,985	NT\$

EY	100	g/kWh
Yield	58.3	kg/day
	1749	kg/month
	20989	kg/year

# 整廠模擬的輸出結果 (ACH = 0.01, indoor CO<sub>2</sub> = 800 ppm, COP = 5.5)

CO <sub>2</sub> balance				CO <sub>2</sub> Price				CO <sub>2</sub> used				
CO <sub>2</sub> supply to room (C <sub>s</sub> )	26.78	mg/(s.room)		20		per day	1.54	kg CO <sub>2</sub>	31	cost,NT\$	Ratio	
Net photos. rate in room (C <sub>N</sub> )	26.06	mg/(s.room)		NT\$/kg		/day/plant	0.0003		0.0051		1.27%	
CO <sub>2</sub> loss by ventilation (C <sub>v</sub> )	0.72	mg/(s.room)				/day/m <sup>2</sup> room	0.0154					
C <sub>s</sub> = C <sub>N</sub> + C <sub>v</sub>						per month	46.27		925			
Water balance				Elec. fee: Light				cost,NT\$				
Transpiration rate of room (T <sub>R</sub> )	3191.1	mg/(s.room)		3.5	Light elec	36.44	kW/room					
(De)Humidification (H)	-3173.7	mg/(s.room)		NT\$/kWh		583	kWh per day		2041		83.8%	
Water loss by ventilation (V <sub>w</sub> )	17.4	mg/(s.room)			Light Period	0.097	kWh /day/plant					
T <sub>R</sub> +H = V <sub>w</sub>					16	5.83	kWh/day/m <sup>2</sup> room					
Energy balance				17491				kWh per month				61,219
k (conductivity of walls) = 0.1				212810				kWh per year				744,834
Total W of lamps (W <sub>L</sub> )	36360.0	W/room		Elec. fee: AC				cost,NT\$				
Total W of other equipment (W <sub>e</sub> )	80	W/room		5.5	AC_elec	6.48	kW/room					
Heat loss by ventilation (Q <sub>v</sub> )	70.3	W/room		COP		104	kWh per day		363		14.9%	
Heat loss by conduction (Q <sub>c</sub> )	720	W/room				0.017	kWh/day/plant					
Heat carry away by AC (Q <sub>a</sub> )	35649.7	W/room				1.037	kWh/day/m <sup>2</sup> room					
W <sub>L</sub> + W <sub>e</sub> = Q <sub>v</sub> + Q <sub>c</sub> + Q <sub>a</sub>						3111	kWh per month		10889			
				37853				kWh per year				132,487
				Capacity of AC required				10.128 RT, Note: 3.52 kW per Refri. Ton				
Operating cost (CO <sub>2</sub> + AC & Light Elec)												
Ratio of OP cost				per day	2434	NT\$	EY	100	g/kWh			
ACH	CO <sub>2</sub>	Light elec	AC elec	per month	73,034	NT\$	Yield	58.3	kg/day			
0.01	1.27%	83.8%	14.9%	per year	888,579	NT\$		1749	kg/month			
								20989				kg/year

## 整廠模擬的輸出結果

(ACH = 0.01, indoor CO<sub>2</sub> = 800 ppm, COP = 5.5)

日產能 (Daily Yield, DY, in kg)

$$DY = EY \times DPC / 1000$$

栽培作物的能源產能 (Energy Yield, EY, in g.kWh<sup>-1</sup>)

日總耗電 (Daily Power Consumption, DPC, in kWh.day<sup>-1</sup>)

$$EY = 100 \text{ g.kWh}^{-1} \text{、} DPC = 583 \text{ kWh.day}^{-1}$$

$$DY = 58.3 \text{ kg,day}^{-1} = 1.749 \text{ 噸/month} = 21 \text{ 噸/Year}$$

# 更多學習

第7章：蒸散

第8章：淨光合速率

光呼吸、暗呼吸、光合速率

栽培面積的計算導入栽培層數與空間利用率的概念，  
 栽培株數以單位面積的栽培密度為基準，  
 由此算出全場的總株數，也增加 LAI 的計算

### Cultivation Room

Room length	10 m	space utilization	0.5	Leaf area/plant	0.1 m <sup>2</sup> /plt
Room width	10 m	No. of layers	4	Number of plants	6000 plt/room
Room height	4 m	Culture area	200 m <sup>2</sup>	Total leaf area	600 m <sup>2</sup>
Room volume	400 m <sup>3</sup>	Cropping density	30 plts/m <sup>2</sup>	LAI	3

$$Tr = 6.9, \quad \text{Leaf area/plant} = 0.1, \quad \text{No. of plants} = 6000$$

$$T_R = 6.9 \times 0.1 \times 6000 = 4140 \text{ mg/s/room}$$

## 燈光所涉及熱能的計算方式

增加輸入每日光照時數，允許光照成本的計算  
燈管使用數量的計算，以單位面積使用的燈管數量為計算基礎

<b>Lighting</b>									
W per LEDtube	20	W/lamp	Number of LEDtubes	1818			PAR		54 W/m2
No.LEDtube/layer	6		PPFD	250	$\mu\text{mol}/\text{m}^2/\text{s}$		DLI	14.4	$\text{mol}/\text{m}^2/\text{day}$
Bench area per layer	0.66	$\text{m}^2$	Light Period	16	$\text{h}/\text{day}$	Power consump. / cural area		181.82	$\text{W}/\text{m}^2$
Total W of other equip ( $W_e$ )			80	$\text{W}/\text{room}$			Total W of lamps	36360.00	$\text{W}/\text{room}$

栽培面積  $200 \text{ m}^2$ ，No. LEDs =  $6 * 200 / 0.66 = 1818$  支燈管  
單位栽培面積耗電瓦數 =  $6 * 20 / 0.66 = 181.82 \text{ W}/\text{m}^2$   
燈光耗電總瓦數 =  $20 * 1818 = 36360 \text{ W}/\text{room}$

<b>CO2 balance</b>	$C_N = 0.71 \times 0.1 \times 6000 = 426$ mg/s/room
CO2 supply to room ( $C_S$ )	443.67 mg/(s.room)
Net photos. rate in room ( $C_N$ )	428.48 mg/(s.room)
CO2 loss by ventilation ( $C_V$ )	15.19 mg/(s.room)
$C_S = C_N + C_V$	

<b>Water balance</b>	$T_R = 6.9 \times 0.1 \times 6000 = 4140$ mg/s/room
Transpiration rate of room ( $T_R$ )	4140.1 mg/(s.room)
(De)Humidification (H)	-3965.8 mg/(s.room)
Water loss by ventilation ( $V_W$ )	174.3 mg/(s.room)
$T_R + H = V_W$	$V_w = 0.1 * 15.7 * 400 / 3.6 = 174.4$

<b>Energy balance</b>	
	$k$ (conductivity of walls) = 0.1
Total W of lamps ( $W_L$ )	36363.6 W/room
Total W of other equipment ( $W_e$ )	80 W/room
Heat loss by ventilation ( $Q_v$ )	703.4 W/room
Heat loss by conduction ( $Q_c$ )	720 W/room
Heat carry away by AC ( $Q_a$ )	35020.2 W/room
	$Q_v = 0.1 * 400 * 55.35 * 1.14 / 3.6 = 701$ W
$W_L + W_e = Q_v + Q_c + Q_a$	
	$Q_c = 0.1 * 2 * (10 * 10 + 20 * 4) * (25 - 5) = 720$ W

分析結果分三部分彙整

二氧化碳平衡：

可求所需提供的二氧化碳施肥速率  
可進而求出二氧化碳施肥成本

水分平衡：

可求出所需除溼機的除溼能力與耗電  
可進而求出除溼機的耗電成本

能量平衡：

可求出空調設備的降溫能力與耗電  
可進而求出空調設備的耗電成本

## 增加三項輸入參數

二氧化碳的成本  
每kWh 的電價  
空調設備的性能係數 COP

## 所需空調的冷卻能力

三項設備的單日、每月與年操作成本  
的彙整與占比的比較  
單日單株成本、單位用地面積成本

CO2 Price			kg CO2	cost,NT\$	Ratio
20	CO2 used	per day	36.95	739	21.52%
NT\$/kg		/day/plant	0.0062	0.1232	
		/day/m2 room	0.3695		
		per month	1108.46	22169	
		per year	13486.23	269,725	
Elec. fee: Light				cost,NT\$	
3.5	Light elec	36.44 kW/room			
NT\$/kWh		583 kWh per day		2041	59.4%
	Light Period	0.097 kWh /day/plant			
	16	5.83 kWh/day/m2 room			
		17491 kWh per month		61,219	
		212810 kWh per year		744,834	
Elec. fee: AC				cost,NT\$	
3	AC_elec	11.67 kW/room			
COP		187 kWh per day		654	19.0%
		0.031 kWh/day/plant			
		1.868 kWh/day/m2 room			
		5603 kWh per month		19609	
		68166 kWh per year		238,580	
Capacity of AC required			9.948 RT, Note: 3.52 kW per Refri. Ton		

Operating cost (CO2 + AC & Light Elec)						
Ratio of OP cost						
				per day	3433	NT\$
ACH	CO2	Light elec	AC elec	per month	102,998	NT\$
0.1	21.52%	59.4%	19.0%	per year	37,594,135	NT\$

CO2 balance		
CO2 supply to room ( $C_S$ )	26.78	mg/(s.room)
Net photos. rate in room ( $C_N$ )	26.06	mg/(s.room)
CO2 loss by ventilation ( $C_V$ )	0.72	mg/(s.room)
$C_S = C_N + C_V$		

Water balance		
Transpiration rate of room ( $T_R$ )	3191.1	mg/(s.room)
(De)Humidification (H)	-3173.7	mg/(s.room)
Water loss by ventilation ( $V_W$ )	17.4	mg/(s.room)
$T_R + H = V_W$		

Energy balance		
k (conductivity of walls) = 0.1		
Total W of lamps ( $W_L$ )	36360.0	W/room
Total W of other equipment ( $W_e$ )	80	W/room
Heat loss by ventilation ( $Q_v$ )	70.3	W/room
Heat loss by conduction ( $Q_c$ )	720	W/room
Heat carry away by AC ( $Q_a$ )	35649.7	W/room
$W_L + W_e = Q_v + Q_c + Q_a$		

CO2 Price	CO2 used	kg CO2	cost,NT\$	Ratio
20	per day	1.54	31	1.13%
NT\$/kg	/day/plant	0.0003	0.0051	
	/day/m2 room	0.0154		
	per month	46.27	925	
	per year	562.94	11,259	

Elec.fee: Light	Light elec	cost,NT\$	Ratio
3.5	36.44 kW/room		
NT\$/kWh	583 kWh per day	2041	74.6%
	Light period	0.097 kWh /day/plant	
	16	5.83 kWh/day/m2 room	
		17491 kWh per month	61,219
		212810 kWh per year	744,834

Elec.fee: AC	AC_elec	cost,NT\$	Ratio
3	11.88 kW/room		
COP	190 kWh per day	665	24.3%
	0.032 kWh/day/plant		
	1.901 kWh/day/m2 room		
	5704 kWh per month	19964	
	69398 kWh per year	242,893	
Capacity of AC required		10.128 RT, Note: 3.52 kW per Refri. Ton	

Operating cost (CO2 + AC & Light Elec)						
Ratio of OP cost				per day	2737	NT\$
ACH	CO2	Light elec	AC elec	per month	82,108	NT\$
0.01	1.13%	74.6%	24.3%	per year	998,985	NT\$

EY	100	g/kWh
Yield	58.3	kg/day
	1749	kg/month
	20989	kg/year

除濕機的規格與電費尚未納入  
此部分與空調的除濕有部分重疊

## HW：以預設數值為基準

- 室內的二氧化碳濃度由400 提高到1200 ppm，成本會增加多少，光合速率會增加多少？
- ACH 由0.01 提高到 0.2，二氧化碳施肥的成本會提高多少？
- 室內維持20 °C，室外溫度由 5 提高到25 °C，同時ACH 由 0.01 至0.2，換氣影響的成本又會如何？
- 其它 ...

THE END

# 兩個版本的比較

千葉大學 vs. 台大

千葉大學的版本

Plant					
Plant type (light)	Std. ▾	Plant type (CO2)	Std. ▾		
Kl	100	GI	0.10		
Kc	440	mg/m <sup>3</sup> Gc	0.79		
CO2 in chloroplast	848.7	ppm = 1663.4	mg/m <sup>3</sup>		
Tm	25	°C	GTl	1.00	Photosynthesis 0.16 mg/(m <sup>2</sup> s)
a	5		Kpr	0.12	Photorespiration 0.02 mg/(m <sup>2</sup> s)
Rd (20C)	0.07	mg/(m <sup>2</sup> s)	Rd	0.10	mg/(m <sup>2</sup> s) Net Photos. 0.04 mg/(m <sup>2</sup> s)

Environment					
Temp. in	25	°C	RH in	80	% Vds in 18.4 g/m <sup>3</sup>
Temp. out	5	°C	RH out	40	% Vds out 2.7 g/m <sup>3</sup>
CO2 in	1000	ppm	1799.5	mg/m <sup>3</sup>	Rlv 1059.7 s/m
CO2 out	380	ppm	733.0	mg/m <sup>3</sup>	Rav 100.0 s/m
Wind	1	m/s			Inc. of Rlv 306.0 s/m
					TR 3.14 mg/(m <sup>2</sup> s)

Culture room					
Room length	10	m	Room width	10	m Room height 5 m
Room volume	500.0	m <sup>3</sup> /room	Culture area	200	m <sup>2</sup> A 0.02 1/h
LA per plant	0.02	m <sup>2</sup> /plant	Num. of plants	100	plants/room

Lighting					
Lamp type	INF ▾	Num. of lamps	200	lamps/room	PPF 51.5 μmol/(m <sup>2</sup> s)
W per lamp	40	W/lamp	U 0.8		PAR 11.2 W/m <sup>2</sup>
F	3500	lm/lamp	M 0.8		Total W of lamp 8000 W/room
We	80	W/room			

CO2 Balance	
CO2 supply to room(CS)	3.0 mg/(s room)
Net photos. rate in a room(CN)	0.1 mg/(s room)
CO2 loss by ventiration(CV)	3.0 mg/(s room)
$C_S = C_N + C_V$	

Water Balance	
Transpiration rate of room(TR)	6.3 mg/(s room)
Humidification(H)	37.3 mg/(s room)
Water loss by ventiration(VW)	43.6 mg/(s room)
Dehumidification(D)	0.0 mg/(s room)
$T_R + H = D + V_W$	

Energy Balance	
Total W of lamps	8000 W/room
Total W of other equipment	80 W/room
Heat loss by ventiration(QV)	176 J/(s room)
Heat loss by conduction(QC)	800 J/(s room)
Heat carried away by AC(QA)	7104 J/(s room)
$W_L + W_e = Q_V + Q_c + Q_a$	

# 主要差異

## 台大版本

- ✓ 增加全廠栽培株數的計算
- ✓ 更改燈光配置與能耗計算方式
- ✓ 增加葉溫的輸入  
計算蒸散時使用的VDD，以葉片內與空氣的水汽密度差為準，不是以飽和空氣與空氣的水氣密度差為基準。千葉大學版本假設葉溫 = 氣溫，所以不需輸入葉溫。
- ✓ 增加 TE 效率 與 LAI 的計算
- ✓ 增加燈光、空調、二氧化碳成本的計算與成本占比的比較

- It is always important to know what kind of lights will be used and how many of them are necessary.
- What are the light quality, duration and intensity required?
- Factors affecting light intensity on the surface of plants:
  1. Distance between lights and plants.
  2. Presence of light reflectors.
  3. Performance of light reflectors
  4. Surrounding environment, such as spacing among plants, color of walls or ceilings, distance of plants and walls, etc.
- An empirical equation is used **in the area of architecture or lighting** which calculate the light intensity with various light sources or room shapes.

燈光在此僅作為室內照明  
不見得適用於植物栽培

$$E = \frac{F \times U \times M \times n}{RA}$$

由 lux 計算  
適合嗎?

$E$  : Average light intensity, lx  
 $F$  : Luminous outputs per lamp, lm  
 $U$  : Coefficient of utilization  
 $M$  : Maintenance factor  
 $n$  : Number of lamps, number  
 $RA$  : Culture area, m<sup>2</sup>

Coefficient of utilization can be obtained from a chart of coefficient of utilization with given room index and reflection ratio.

$$R = \frac{R_L \times R_W}{R_H \times (R_L + R_W)}$$

$R$  : Room index

$R_L, R_W, R_H$ : Room length, width, height, m

## 2240 lux = PPFD

WL 8000 W

## Simulation

W per lamp 40 W/lamp

F 3500 lm/lamp

Num. of lamps 200 lamps/room

U 0.8

M 0.8

Culture area 200 m<sup>2</sup>

PPF 25.7 μmol/(m<sup>2</sup> s)

PAR 5.6 W/m<sup>2</sup>

Total W of lamps 8000 W/room

Fluorescent lamp 5000K 30.22

Natural daylight 39.65

Halogen lamp 3000K 77.47

High CRI LED 6500K 38.6

High CRI LED 4000K 39.92

HPS 2000K 29.06

Red LED 650 nm 172.14


Blue LED 450 nm 258.84

Red+Blue LED 198.76

Red+Blue+White LED  
450+650nm+3500K 57.54

PPF 25.7 μmol/(m<sup>2</sup> s)  
PAR 5.6 W/m<sup>2</sup>

FL 燈管的數值



**The coefficient of utilization (U):** The % of light irradiated from light sources reaches the surface of plants. It is estimated 70% in efficient PAL.

**The maintenance factor (M)** accounts for deterioration of light sources by aging. A number of 60% for fluorescent lamps that have been used for a few year.

**Fluorescent lamp only** 由 lux 轉換為光量子數與輻射能，可信嗎？

assumed that 87 lx is equal to 1 μmol/(m<sup>2</sup> s) or 0.218 W/m<sup>2</sup>.

$$\begin{aligned} \text{WL (total W of lamps)} &= \text{W/lamp} * n \\ &= 40 * 200 = 8000 \text{ W} \end{aligned}$$

$$\begin{aligned} E &= (F U M n) / R_A \\ &= 3500 * 0.8 * 0.8 * 200 / 200 \\ &= 2240 \text{ lm/m}^2 = 2240 \text{ lux} \end{aligned}$$

$$\text{PPF} = E / 87 = 25.7 \text{ μmol/m}^2/\text{s}$$

$$\text{PAR} = \text{PPF} / 4.589 = 5.6 \text{ W/m}^2$$

台大版本增加葉溫輸入功能，允許空氣溫度與葉溫不同的計算，蒸散的計算改成以葉溫為準

## Environment

	Temperature	RH		density = 1/SV	Vps	ah	enthalpy, kJ/kg		
Leaf (oC)	25	RHleaf, %	100	1.14	3.17			Vds leaf	23.0 g/m <sup>3</sup>
indoor (oC)	25	RHin, %	80	1.14	3.17	0.016	65.77	Vd in	18.4 g/m <sup>3</sup>
outdoor (°C)	5	RHout, %	40	1.23	0.87	0.002	10.42	VDD	4.6 g/m <sup>3</sup>
CO2 indoor (ppm)	1200	-> mg/m <sup>3</sup>	2157.5	1.80				Vd out	2.7 g/m <sup>3</sup>
CO2 outdoor (ppm)	410	-> mg/m <sup>3</sup>	790.2	1.93				Rav	100.0 s/m
Wind (m/s)	1	m/s						Rlv	200.0 s/m
			CropType	high	std	low		Rlv.inc	366.9 s/m
			Rlv =	300	200	100			
ACH	0.02	1/h						Rv.total	666.9 s/m
			CropType	std	low				
			Rlv.inc =	366.9	183.5			TR	6.90 mg/(m <sup>2</sup> .s)

$$dh = 65.77 - 10.42 = 55.35 \text{ kJ/kg}$$

$$\text{Vol} = 400, \text{ACH} = 0.02, \text{density} = 1.14$$

$$dh \text{ per room} = 0.02 * 400 * 55.35 * 1.14 / 3.6 = 140.22$$

$$\text{If ACH} = 0.1, dh \text{ per room} = 140.22 * 5 = 701 \text{ W/room}$$

$$dVd = (18.4 - 2.7) = 15.7 \text{ g/m}^3, \text{ACH} = 0.1$$

$$\text{Water loss by ventilation} = 0.1 * 15.7 * 400 / 3.6 = 174.4 \text{ mg/s/room}$$

允許選擇不同作物種類：針對輻射量有三個選項，針對二氧化碳濃度有兩個選項  
程式可自動選擇計算使用的參數值